

Outward NO. AMC/FIRE/1220/2010
Fire Brigade Municipal Corporation
Aurangabad 28/12/2010

To,
MR SHRI K. S. TRIVEDI ITS SHRI B. S.
TRIVEDI THROUGH ITS G.P.A/PARTNER
SHRI SUYOG RUNWAL GUT NO-45,
AT NAKSHTRAWADI, PATHAN thoroughfare
TO DIST- AURANGABAD

SUB- Provisional Fire NOC issued to the Commercial - Building cum Residential
High- Building MR SHRI B.S TRIVEDI ITS MR SHRI K. S TRIVEDI
THROUGH ITS G.P.A/PARTNER SHRI SUYOG RUNWAL GUT NO 45
AT NAKSHTRAWADI, PATHAN ROAD TO DIST- AURANGABAD

Ref :- 1 Your Letter dated on 28/10/2010

With reference to the above subject Provisional Fire NOC is issued to the
Commercial Building cum Residential high building MR SHRI B.S TRIVEDI ITS
MR SHRI K. S TRIVEDI THROUGH ITS G.P.A/PARTNER SHRI SUYOG RUNWAL
GUT NO-45 AT NAKSHTRAWADI, PATHAN ROAD TO DIST- AURANGABAD
TOTAL LAND AREA - 1,28,409.00 Sqmtr

- 1) G-F building total 4- built up area 1975.50 sqmtr each height of Building is 24.00 mtr
- 2) G-C building total 4- built up area 13,558.34 sqmtr each height of Building is 24.00 mtr
- 3) A-1B-2 building total 2 built up area 5956.24.00 sqmtr each height of Building is 24.00 mtr
- 4) A-2B-4 building total 2 built up area 5956.24.00 sqmtr each height of Building is 24.00 mtr
- 5) A-1B-2 building total 2 built up area 1710.86 sqmtr each height of Building is 24.00 mtr
- 6) school building - 1- built up area 5125.00 sqmtr height of Buildings 15.20 mtr
- 7) commercial building - 1 Building built up area 404.82 sqmtr height of Building is 13.00 mtr

total 16 sixty six children is total built up area 24,694.32 sqmtr Owners has paid
total 16 sixty building capitulation fees of Rs. 20,875/- in Fire Brigade by receipt
NO 398927 dated 30-10-2010

Following Fire Prevention and Fire Protection & Fighting measures Subject to the
Commercial cum Residential high rise Building shall be provided

- 1 Each building 06 mtr Open space all around the building shall be provided for free
Movements of fire tender which will carry 25 tons Weight capacity
- 2 Each building Underground water tank of 50,000 and Over head Fire water tank
Of 10000Ltrs Capacity with Fire pump of suitable capacity for building shall be
Provided
- 3 Each building Fire service inlet 4 ways incoming shall be provided
- 4 Each building 8-No hydrant points all round the building with fire hose pipe/branch
Shall be provided Commercial
- 5 Each building Wet-riser cum down corner having out lets on all floors with hose
pipe /branch shall be provided
- 6 Each building External approach Fire Escape staircase of 1.5 mtr width shall be
Provided
- 7 Each building Hose reel of 100 feet on all out lets be provided




Principal

SHAMIT SCHOOL
Shamit Octozone Gut No. 4:
Nakshatrawadi, Aurangabad



8. Each building Fire Extinguisher of DCP/CO2/Soda acid /Fire buckets of suitable Capacity /quantity shall be provided.
9. Each building Fire alarm system/Detector System /Public Address System /Control Panel shall be provided.
10. Each building requirements shall be carried out with prior approval from Fire Brigade shall be provided.
11. Each building Refuge areas above 18m high should be Provided.

BPMC ACT -1949 Section 376, Development Control Rules of 1983 and MAHARASHTRA Fire prevention its Life Safety Measures Act 2006 AMC PROVISIONAL FIRE - NOC is issued to the Commercial Building cum Residential high-rise building MR SHRI B.S. TRIVEDI ITS MR SHRI K. S. TRIVEDI THROUGH G.P. AJ PARTNER, SHRI SUYOG, RUNWAL GUT-NO 45 AT NAKSHTRAWDI PATHAN ROAD TO, DIST. AURANGABAD


Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:
A.D. T.P. AMC, Aurangabad






Principal
SHAMIT SCHOOL
Shamit Octozone Gut No.
Nakshatrawadi, Aurangabad

